

Susquehanna Valley Central Schools
2019 Radon Study

Action level=4pCi/L

| BUILDING | ROOM | Results in pCi/L |
|------------------|-------------|-------------------------|
| | | |
| | | |
| Brookside | Rm 14 | 0.6 |
| | Rm 41 | 1 |
| | Rm 42 | 0.5 |
| | Rm 15 | 0.7 |
| | Rm 15 | 1.2 |
| | Rm 3 | 1.9 |
| | Rm 8 | 0.6 |
| | Rm 5 | 0.7 |
| | Rm 4 | 1.4 |
| | Rm 9 | 0.1 |
| | Rm 7 | 0.1 |
| | Rm 2 | 0.6 |
| | Rm 2 | 0.7 |
| | Café | 0.8 |
| | Café | 0.7 |
| | Rm 42 | 0.4 |
| | Rm 19 | 5.2 * |
| | Rm 21 | 2.1 |
| | Rm 12 | 0.1 |
| | Rm 23 | 1.5 |
| | Rm 26 | 2.7 |
| | Library | 0.6 |
| | Library | 0.7 |
| | Rm 18 | 1 |
| | Rm 24 | 3.6 |
| | Rm 27 | 1.4 |
| | Rm 16 | 1.1 |
| | Rm 17 | 3.6 |
| | Rm 25 | 1.4 |
| | Rm 28 | 2.8 |
| | Rm 22 | 1 |
| | Rm 10 | 0.3 |
| | Rm 1 | 3 |
| | Music 1 | 0.4 |
| | Music 2 | 0.3 |
| | Rm 20 | 0.4 |
| | Trip blank | 0.1 |
| | Rm 6 | 0.6 |
| | Rm 13 | 0.2 |
| | Rm 11 | 0.5 |

* Room 19 post-remediation level 1.6

Susquehanna Valley Central Schools
2019 Radon Study

Action level=4pCi/L

| <u>BUILDING</u> | <u>ROOM</u> | <u>Result in pCi/L</u> |
|-----------------|-------------|------------------------|
| | | |
| | | |
| Donnelly | Rm 5 | 0.7 |
| | Trip blank | 0.1 |
| | Rm 6 | 0.3 |
| | Rm 7 | 0.9 |
| | Rm 3 | 0.9 |
| | Café 1 | 1 |
| | Café 2 | 1.1 |
| | Rm 12 | 0.4 |
| | Rm 19 | 0.8 |
| | Rm 21 | 3.8 |
| | Rm 13 | 1 |
| | Rm 24 | 2 |
| | Rm 24 | 1.7 |
| | Rm 25 | 2.8 |
| | Library | 1.8 |
| | Library | 1.5 |
| | Rm 10 | 0.2 |
| | Rm 9 | 0.4 |
| | Rm 1 | 1.8 |
| | Rm 11 | 0.5 |
| | Rm 23 | 1.7 |
| | Rm 2 | 1.4 |
| | Rm 26 | 2.1 |
| | Rm 20 | 2.6 |
| | Rm 8 | 0.8 |
| | Rm 4 | 1.1 |
| | Rm 22 | 2.8 |
| | Rm 27 | 2.6 |

Susquehanna Valley Central Schools
2019 Radon Study

Action level = 4pCi/L

| <u>BUILDING</u> | <u>ROOM</u> | <u>Result in pCi/L</u> |
|-----------------|-------------|------------------------|
| | | |
| | | |
| MS | Rm 113 | 2.8 |
| | Library 1 | 1.6 |
| | Library 2 | 1.5 |
| | Rm 116 | 0.1 |
| | Rm 106 | 1.6 |
| | Rm 103 | 0.3 |
| | Rm 118 | 1.4 |
| | Rm 122 | 1.8 |
| | Rm 104 | 0.5 |
| | Café 1 | 0.3 |
| | Café 2 | 0.5 |
| | Rm 126 | 3.3 |
| | Rm 102 | 0.7 |
| | Rm 124 | 2.6 |
| | Rm 123 | 0.5 |
| | Rm 105 | 0.3 |
| | Rm 115 | 1.4 |
| | Rm 120 | 0.7 |
| | Rm 117 | 1.6 |
| | Rm 114 | 0.5 |
| | Rm 109 | 0.5 |
| | Rm 101 | 0.1 |
| | Rm 127 | 1.3 |
| | Rm 108 | 0.5 |
| | Rm 121 | 0.3 |
| | Rm 119 | 0.5 |
| | Rm 110 | 0.6 |
| | Rm 125 | 1 |
| | Trip Blank | 0.1 |
| | Rm 107 | 2 |

| | A | B | C |
|----|-----------------|-------------|------------------------|
| 1 | BUILDING | ROOM | Result in pCi/L |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | HS | Rm 28 | 1.5 |
| 6 | | Rm 20 | 1.2 |
| 7 | | Rm 26 | 2 |
| 8 | | Rm 15 | 1.2 |
| 9 | | Rm 27 | 1.6 |
| 10 | | Rm 22 | 1.4 |
| 11 | | Rm 25 | 1.4 |
| 12 | | Library 1 | 1.2 |
| 13 | | Library 2 | 1.6 |
| 14 | | Liberty 31 | 0.6 |
| 15 | | Rm 16 | 0.8 |
| 16 | | Rm 37 | 1.8 |
| 17 | | Rm 35 | 0.9 |
| 18 | | Rm 23 | 1.6 |
| 19 | | Rm 17 | 0.1 |
| 20 | | Rm 41 | 0.1 |
| 21 | | Rm 23A | 2.9 |
| 22 | | Café1 | 0.5 |
| 23 | | Café 2 | 0.5 |
| 24 | | Rm 30 | 0.1 |
| 25 | | Rm 36 | 1 |
| 26 | | Rm 18A/B | 0.4 |
| 27 | | Rm 40 | 2.2 |
| 28 | | Rm 24 | 1 |
| 29 | | Rm 44 | 1.6 |
| 30 | | Rm 33 | 1.3 |
| 31 | | Rm 58 | 1.4 |
| 32 | | Rm 42 | 1.8 |
| 33 | | Rm 14 | 1.2 |
| 34 | | Band 57 | 1.2 |
| 35 | | Rm 45 | 1.7 |
| 36 | | Rm 48 | 1.1 |
| 37 | | Rm 6 | 2.3 |
| 38 | | Trip blank | 0.1 |
| 39 | | Rm 1 | 1.2 |
| 40 | | Rm 13 | 1.7 |
| 41 | | Rm 46 | 0.7 |
| 42 | | Rm 47 | 1.2 |
| 43 | | Rm 4 | 1 |
| 44 | | Rm 1 | 1.6 |
| 45 | | Rm 12 | 1.8 |
| 46 | | Rm 3 | 0.8 |
| 47 | | Rm 29 | 1.4 |
| 48 | | Rm 7 | 2 |
| 49 | | Rm 34 | 2.6 |
| 50 | | Rm 43 | 0.1 |
| 51 | | Rm 21 | 1.3 |
| 52 | | Aud 1 | 1 |
| 53 | | Aud 2 | 0.8 |
| 54 | | Rm 19 | 0.4 |
| 55 | | Rm 2 | 1.4 |
| 56 | | Rm 52 | 2 |
| 57 | | Rm 5 | 0.7 |